



Certificate / Certificat Zertifikat / 合格証

MAR 091051 C003

exida hereby confirms that the:

**Series 39 & 39M
3-Way Ball Valves**

The manufacturer
may use the mark:



Revision 4.1 May 11, 2020
Surveillance Audit Due
May 1, 2023

**Mars Valve Co., Ltd.
Taichung, Taiwan – R.O.C.**

Has been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-7

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFD_{avg} and Architecture Constraints
must be verified for each application**

Safety Function:

The Ball Valve will move to the designed safe position per the actuator design within the specified safety time.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



Deymond Lee
Evaluating Assessor

Steva J. Chase
Certifying Assessor

ISO/IEC 17065
PRODUCT CERTIFICATION BODY
#1004

MAR 091051 C003

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

PFD_{avg} and Architecture Constraints must be verified for each application

Systematic Capability :

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2_H.

IEC 61508 Failure Rates in FIT*

Application/Configuration	λ_{SD}	λ_{SU}	λ_{DD}	λ_{DU}
Full Stroke, Clean Service	0	0	0	420
Tight Shut-Off, Clean Service	0	0	0	1156
Open on Trip, Clean Service	0	121	0	299
Full Stroke, Severe Service	0	0	0	792
Tight Shut-Off, Severe Service	0	0	0	2264
Open on Trip, Severe Service	0	241	0	551

* FIT = 1 failure / 10⁹ hours

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD_{AVG} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: MAR_Q091051_R004_V4R1 (or later)

Safety Manual: 25-04-07 Safety Manual 3-Way Ball Valve



80 N Main St
Sellersville, PA 18960

Series 39 & 39M
3-Way Ball Valves